

INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH THIRUVANANTHAPURAM (IISERTVM) (Govt. of India, Ministry of H.R.D)

Рн: 0471-2597454 Fax:0471-2597427

EMAIL: PURCHASESTORES@JISERTVM.AC.IN

CET CAMPUS, KULATHUR, ENGINEERING COLLEGE.P.O
THIRUVANANTHAPURAM 695016,
KERALA, INDIA.

Date: 08th May 2015

INVITATION TO TENDER(IND)

No: IISER/PUR/5586/14
Due Date: 26th May 2015 [4PM]

Date of Opening: 27th May 2015 [3PM]

Dear Sirs,

Sub: Supply of Supply, Installation, Testing & Commissioning of Split AC Units

We require the following items immediately:

Sl No:	Item/ Description	Qty
1.	Supply, Installation, Testing and Commissioning of 1.5TR Split	2 Nos
	units [Specifications as per Annexure I]	2 1103

Please quote your lowest rate and shortest delivery period as per the following terms. Your offer in sealed cover **SUPERSCRIBING TENDER NUMBER AND DUE DATE** shall reach us on or before the due date and time.

Payment

: Within 30 days after supply and installation/Net 30 days /LC. No

Advance Payment will be made by IISERTVM.

Delivery

: To be delivered at our stores (Free delivery). If import, mention

Ex-works/FCA/CIP terms with clear breakup charges.

Warranty

: For a minimum period of one year from the date of supply

and installation

Taxes & Duties

: Indicate taxes and duties. We are exempted for customs duty

under 51/96 notification and Excise duty under 10/97

notifications.

Discount

: Indicate, if any.

Delivery Schedule

: Required Immediately. Indicate your schedule

Validity of quote

: 60 days

Thanking You,

Yours Faithfully

K. BHASKARA RAO Deputy Registrar (Purchase & Stores)

- P.S. (1) OUR PREVIOUS TENDER OF EVEN NO. DATED 01ST APRIL 2015 (DUE DT 16TH APRIL 2015) STANDS CANCELLED AND THIS IS A RETENDER.
 - (2) CATALOGUE/LEAFLET FEATURING ALL TECHNICAL SPECS/INFORMATION OF THE PRODUCT QUOTED SHALL ACCOMPANY THE OFFER.

ANNEXURE I TO ENQUIRY NO. IISER/PUR/5586/14 DATED 08TH MAY 2015

Specifications:

- > 1.5 ton, 5 star Split Air Conditioner with voltage stabilizer.
- ➤ Nominal capacity: 1.5 ton
- ➤ Cooling capacity: 5.25kW ± 2%
- ➤ Electricity input: 230V/50Hz/Single Phase
- > Coefficient of performance: 3.5 (minimum)
- ➤ Max. Ambient temperature: 48DegC ± 5%
- ➤ Moisture removal rate: 2 ± 10% litre/hour
- > Air Flow rate : 5.6cmm (Minimum)
- Noise level Indoor unit: Less than 45 db
- > Outdoor unit: Less than 55 db
- Function Modes: Auto/Cool/Fan/Dry -shall have sleep and power saving modes
- > Other Features: Automated vertical swing for horizontal louvers, Antifreeze thermostat
- > Compressor: Rotary type.
- > Body surface finish: Powder coated/high quality paint finish
- > Air filtering unit: Activated carbon cartridge, dust prof and anti-bacteria filter
- ➤ Length of tubing's: Copper connecting kit with 15m or as per the installation requirement.
- > Remote handset: LCD display with night glow
- ➤ Voltage stabilizer: Stabilizer having ISI quality certification and power rating that matches with the power rating of the A/C unit.

K. BHASKARA RAO Deputy Registrar [Purchase & Stores]